

1 General information

Facility /System Name: Town of Wilkesboro Sanitary Sewer Collection System

Responsible Entity: Town of Wilkesboro

Person in Charge/Contact: Jason Hart

Applicable Permit(s): WQCS000051

Description of Collection System or Treatment Process

The Town of Wilkesboro owns and maintains approximately 61.3 miles of sewer outfall, trunk, and lateral lines with 1.6 miles of force mains.

Pipe sizes range from 2" up to 24". The pipe materials include VCP, Ductile Iron, PVC, and HDPE.

The Collections System contains 1415 Manholes

The Collections System contains 5 Lift Stations

We also help maintain(if needed) 8.11 miles of gravity sewer, 6.9 miles of force sewer, and 136 Manholes of private lines.

2 Performance

Text Summary of System Performance for the calendar year of 2024.

The system has performed very well in the past 12 months. There have been two violations, both **non-reportable** for the year. A continuous effort of preventive maintenance and public education by the Town enables this system to perform at a high level.

List by month any violation of permit conditions or other environmental regulations.

Monthly lists should include discussion of any environmental impacts and measures taken to address violations.

First occurrence was on 09-27-24 at Central Wilkes Lift Station. There were no excessive environmental impact. Basic cleanup procedures were taken. Approximately 400 to 500 gallons (**Non-reportable**). This was due to infiltration from Hurricane Helene, we have identified problem areas and are working towards getting the infiltration reduced as much as possible.

Second occurrence was on 10-20-24 at SMH-79 which is a private manhole. There were no excessive environmental impact. Basic cleanup procedures were taken. Approximately 200-300 gallons (**Non-reportable**). This was due to paper towels from restaurants being flushed. We have spoken to all restaurants above said manhole and instructed them to move their paper towel dispenser.

3 Notification


State how this report had been made available to users or customers of the sysytem and how those users have been notified of its availability.

Copies of this report may be obtained at the Public Works Dept. at 1302 N. Collegiate Dr. Wilkesboro, NC 28697. Notice will also be posted on the Town's website.

4 Certification

I certify that under the penalty of law that this report is complete and accurate to the best of my knowledge.

I further certify that this report has been made available to the users or customers of the named system.

A handwritten signature in black ink, appearing to read "Jason Hart", is written over a horizontal line.

Jason Hart, ORC
Town of Wilkesboro